

Consenting & Compliance Group

Construction Statement – solid/liquid fuel heater

This statement must be completed by the installer and be provided to the building inspector at the time of the inspection.

TO: Christchurch City Council Building Consent Authority

Issued by: *(name of installer)*

In respect of building consent number: At: *(project address)*

<input type="text"/>	<input type="text"/>
----------------------	----------------------

In relation to the installation of a:

<input type="checkbox"/> solid fuel heater	<input type="checkbox"/> liquid fuel heater	<input type="checkbox"/> free-standing	<input type="checkbox"/> in-built	<input type="checkbox"/> insert
--	---	--	-----------------------------------	---------------------------------

Make:

Model:

Serial No:

<input type="text"/>	<input type="text"/>	<input type="text"/>
----------------------	----------------------	----------------------

[Select as appropriate]

	Yes	No	N/A
The existing chimney has been cleaned and inspected for soundness prior to installation.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The fireplace surround / chimney face junction is sealed up with heat resistance material.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The flue pipe is constructed of austenitic stainless steel.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Seismic restraint has been fitted.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The flue sections are secured together with stainless steel rivets.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The flue is secured to the appliance.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Flue/enclosure has been vented.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Flue and appliance clearances have been achieved in terms of the manufacturer's installation instructions and AS/NZS 2918.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The flue height meets the minimum specified in the manufacturer's instructions and Environment Canterbury (ECan) rules.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Flue flashing has been installed as specified in the manufacturer's installation instructions.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The roofing underlay has been installed/repared around flue penetration.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Smoke detectors (with hush facility) as detailed on the building consent documents are installed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Connection or re-connection of wetback undertaken by Certifying Plumber, and details of this provided on form B-011 (Application for a code compliance certificate).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<i>Note: It is an offence under the Plumbers, Drainlayers and Gasfitters Act 2006 for unlicensed and unqualified persons to undertake this work.</i>			

[Select as appropriate]

	Yes	No	N/A
For NEW wetback connections, anti-scald device installed and copy of B-084 (Construction Statement – Pipework Testing) attached, completed and signed by the Certifying Plumber.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Liquid Fuel only: The appliance has been installed and commissioned in accordance with the manufacturer's installation and operating instructions, a copy of commissioning certificate is attached.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The liquid fuel storage tank and feed system has been installed in accordance with AS1691, or equivalent, and with the requirements of the Council's Environmental Health Officer.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
The fuel storage tank has secondary containment (100% if roofed, 120% if unroofed) in accordance with the proposed City Plan. <i>Note: Audit monitoring will be carried out.</i>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

If response to any of the items is no, please comment:

I (print name) certify that the above specified installation has been carried out as described and in accordance with the manufacturer's installation instructions and the current approved building code requirements.

Installer's Signature:	Date:	Registration No:
<input type="text"/>	<input type="text"/>	<input type="text"/>

I also understand that the Christchurch City Council, in accepting this construction statement, may be relying on it to issue the code compliance certificate at the completion of the building work.